

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302

CHEMICAL TREATMENT REPORT

Customer Jacobs Landing City Shueyville, IA

Date March 23, 2018 Well Number 2 Location _____

Well Depth 530 Well Top Size 8" Size of Casing 8"

	<u>Before Treatment</u>		<u>After Treatment</u>
S.W.L	<u>182</u>	S.W.L	<u>260</u>
G.P.M	<u>35</u>	G.P.M	<u>60</u>
Pumping Level	<u>430</u>	Pumping Level	<u>400</u>
Yield Per Ft. of D.D.	<u>0.14</u>	Yield Per Ft. of D.D.	<u>0.375</u>

Describe Treatment

Air shock development

Pressure acidization

Airlift development

Chemicals Used

660 Gallons of muratic inhibited acid

Condition of Pumping Equipment

Test pump

Pump Information:

Pump Model Number	<u>150S200</u>
Stages	<u>10</u>
Air Line Length	<u>430</u>
Pump Setting	<u>430</u>
Size of Column	<u>3"</u>
Motor HP, Volt	<u>20hp./460 volt</u>
Running Amperage	<u>31</u>