

Kirby Valley View Mobile Court

Owner Victor and Marian Kirby

Located Harrison County ST Johns Township.

Well #1 Street side Pump house

Constructed by Rotary Reg 7" Borehole

No Top Soil

1'-30' - Brn clay

30'-45' - Red clay

45'-62' - Brn Clay Lime mixture

62'-78' - Sandy Soft Blue Clay

78'-117' - Firm Blue Clay Sand mix

117'-126' - Coarse gravel

126'-133' - Hard Blue water tight clay

133'-156' - Sand Gravel Mix -

156' - Limerock White

Well Drilled with out lost water or Tools

Water Static level 90' below grd level

Pumped w sub pump @ 30 gal/min pump level 95'

4" PVC Sch 40 pipe casing

3 PVC .025 slot

Plastic cap on bottom

