

89746 *page 1*

Oasis Well & Pump Co.

1332 N. Franklin St
Manchester, Ia 52057
563-927-6603
888-666-6603

WELL TEST DATA REPORT

Customer Outback Lodge & Camp City Monticello, Iowa
 Location 19599 242 Street Monticello Well No. PWSID # 5343402
 Size Casing 6" ID Steel Total Depth 463' Construction _____
 Make Pump _____ Model No. _____ No. of Stages _____
 Diameter _____ Total Setting 400' Air Line Length Yes
 Meter Used Yes Static Level 260'

DATE	TIME	GPM	P.L.	Draw Down D.D.	S.C.	WATER LEVEL P.S.I.	TEMP DISCHARGE DESCRIPTION
10-15-18	9:24 am	44	400'			260'	
	9:27	44				270'	
	9:28	44					
	9:29	44					
	9:30	44					
	9:31	44					
	9:32	44					
	9:33	44		30'		290'	
	9:34	44				290'	
	9:35	44				290'	
	9:36	44				290'	
	9:37	44				290'	
	9:38	44				290'	
	9:39	44				290'	
	9:40	44				290'	
	9:41	44				290'	
*	9:44	44				290'	
	9:47	44				290'	
	9:50	44				290'	
	9:53	44				290'	
	9:56	44				290'	
	10:01	44				290'	
	10:06	44				290'	
	10:11	44				290'	
	10:16	44		40'		300'	
	10:21	44				300'	
	10:26	44				300'	
*	10:36	44				300'	
	10:46	44				300'	
	10:56	44				300'	
	11:06	44				300'	
	11:16	44				300'	
	11:26	44				300'	
	11:36	44				300'	
	11:46	44				300'	
	11:56	44				300'	
	12:06 pm	44				300'	
	12:16	44				300'	
	12:26	44				300'	
*	1:26	44				300'	
	2:26	44				300'	

89746 (Page 2)

Oasis Well & Pump Co.

**1332 N. Franklin St
Manchester, Ia 52067
563-927-8503
888-888-8503**

WELL TEST DATA REPORT

Customer	Outback Cabins + Camping		City	Monticell Iowa	
Location			Well No.	PWSID # 534340L	
Size Casing	6" ID Steel	Total Depth	463'	Construction	
Make Pump		Model No.		No. of Stages	
Diameter		Total Setting	400'	Air Line Length	Yes
Meter Used	Yes	Static Level	260'		

DATE	TIME	GPM	P.L.	Draw Down D.D.	S.C.	Water Level/ P.S.I.	TEMP DISCHARGE DESCRIPTION
	3:26		400'			300'	
	4:26		1			300'	
	5:26					300'	
	6:26					300'	
	7:26					300'	
	8:26					300'	
	9:26					300'	
	10:26					300'	
	11:26					300'	
10-16-18	12:26am					300'	
	1:26					300'	
	2:26					300'	
	3:26					300'	
	4:26					300'	
	5:26					300'	
	6:26					300'	
	7:26					300'	
	8:26					300'	
	9:26					300'	
10-16-18	9:30AM	TOOK	Nitrate	Water Sample			
	9:31AM	TOOK	Bacteria	WATER Sample			
	9:35AM	SHUT	OFF TEST PUMP			300'	
	9:38AM					280'	
	9:45AM					270'	
	9:55AM					270'	
	11:00pm	Dropped off WATER SAMPLES at Hydrotec Lab AT San Jose San Jose City					