

HOWARD M. WHITE & SON
HOEG & AMES, Inc.

WATERLOO, IOWA
LINCOLN, IOWA
Sheet No. 1

WELL PRODUCTION TEST DATA SHEET

Job Town of Malcom Date Tested September 4, 1979
Location South West Corner of Town Tested by Howard White & Jim Reisener
Diameter of Well 6" Pump Used Line Shaft Turbine
Depth of Well 220' Driver Diesel
Length of Airline Electric Col. & Shaft 4 X 1
Static W. L. 66' Bowls 6"
Orifice Size 3" X 6" Mfr.

TIME	ORIFICE READING	GPM	PUMPING LEVEL	STATIC W. L.	DRAW- DOWN	REMARKS
3:12 PM	6	82	70'	66'	4'	
3:13	6½	85	71' 2"	"	5' 2"	Water Clear
3:14	6½	85	72' 1"	"	6' 1"	
3:15	6½	85	73'	"	7'	
3:16	6½	85	73'	"	7'	Speeded up Pump to 14"
3:25	14	123	79' 3"	"	13' 3"	
3:30	"	"	80' 4"	"	14' 4"	
3:35	"	"	81' 2"	"	15' 2"	
3:40	"	"	81' 9"	"	15' 9"	
3:45	"	"	82' 2"	"	16' 2"	
4:00	"	"	83' 8"	"	17' 8"	
4:15	"	"	84' 9"	"	18' 9"	
4:30	"	"	84' 7"	"	18' 7"	
4:45	"	"	84' 6"	"	18' 6"	
5:00	"	"	87' 2"	"	21' 2"	
5:15	"	"	87' 6"	"	21' 6"	
5:30	"	"	87' 10"	"	21' 10"	

HOWARD M. WHITE & SON

HOEG & AMES, Inc.

WATERLOO, IOWA

LINCOLN, IOWA

Sheet No. 2

34978

WELL PRODUCTION TEST DATA SHEET

Job _____ Date Tested _____
 Location _____ Tested by _____
 Diameter of Well _____ Pump Used _____
 Depth of Well _____ Driver _____
 Length of Airline _____ Col. & Shaft _____
 Static W. L. _____ Bowls _____
 Orifice Size _____ Mfr. _____

TIME	ORIFICE READING	GPM	PUMPING LEVEL	STATIC W. L.	DRAW- DOWN	REMARKS
6:00 PM	14	123	89' 1"	66'	23' 1"	
6:30	"	"	90' 5"	"	24' 5"	
7:00	"	"	90' 2"	"	24' 2"	
7:30	"	"	90' 9"	"	24' 9"	
8:00	"	"	91' 4"	"	25' 4"	
8:30	"	"	91' 10"	"	25' 10"	
9:00	"	"	92' 4"	"	26' 4"	
9:30	"	"	92' 10"	"	26' 10"	
10:00	"	"	93' 4"	"	27' 4"	
10:30	"	"	93' 10"	"	27' 10"	
11:00	"	"	94' 1"	"	28' 1"	
11:30	"	"	94' 4"	"	28' 4"	
12:00 Midnight	"	"	94' 5"	"	28' 5"	
12:30 AM	"	"	94' 10"	"	28' 10"	
1:00	"	"	95'	"	29'	
1:30	"	"	94' 8"	"	28' 8"	
2:00	"	"	94' 6"	"	28' 6"	

HOWARD M. WHITE & SON
HOEG & AMES, Inc.

WATERLOO, IOWA
LINCOLN, IOWA
Sheet No. 3

WELL PRODUCTION TEST DATA SHEET

Job _____ Date Tested _____
Location _____ Tested by _____
Diameter of Well _____ Pump Used _____
Depth of Well _____ Driver _____
Length of Airline _____ Col. & Shaft _____
Static W. L. _____ Bowls _____
Orifice Size _____ Mfr. _____

TIME	ORIFICE READING	GPM	PUMPING LEVEL	STATIC W. L.	DRAW- DOWN	REMARKS
2:30 AM	14	123	94' 6"	66'	28' 6"	
3:00	"	"	"	"	"	
3:30	"	"	"	"	"	
4:00	"	"	"	"	"	
4:30	"	"	"	"	"	
5:00	"	"	"	"	"	
5:30	"	"	"	"	"	
6:00	"	"	"	"	"	
6:30	"	"	"	"	"	
7:00	"	"	"	"	"	
7:30	"	"	"	"	"	
8:00	"	"	"	"	"	
8:30	"	"	"	"	"	
9:00	"	"	"	"	"	
9:32	"	"	"	"	"	Shut off pump
9:34				94' 6"		
9:35				94' 0"		

HOWARD M. WHITE & SON

HOEG & AMES, Inc.

WATERLOO, IOWA

LINCOLN, IOWA

Sheet No. 4

3497

WELL PRODUCTION TEST DATA SHEET

Job _____ Date Tested _____
 Location _____ Tested by _____
 Diameter of Well _____ Pump Used _____
 Depth of Well _____ Driver _____
 Length of Airline _____ Col. & Shaft _____
 Static W. L. _____ Bowls _____
 Orifice Size _____ Mfr. _____

TIME	ORIFICE READING	GPM	PUMPING LEVEL	STATIC W. L.	DRAW- DOWN	REMARKS
9:36AM				93' 8"		
9:37				93' 2"		
9:42				91' 7½"		
9:47				90' 5"		
10:00				83' 3"		
10:20				81' 7"		
10:35				80' 11"		
10:45				80' 5"		
11:07				79' 6"		
11:15				79' 3"		
11:30				78' 10"		
11:45				78' 5"		
12:00 Noon				78' 0"		
12:15				77' 9"		
12:30				77' 4"		