

**WARNER WELL & PUMP CO.**  
DUBUQUE, IOWA

**WELL TEST DATA SHEET**

Job Oxford Junction

Date tested August 8, 1977

Location City Well #2

Tested by Varner--Paul Gatewood

Dia. of well 8"

Pump used: Driver 471 Detroit

Depth of well 50'

Column and shaft 4" x 1"

Length of airline Electric Probe

Bowls Peerless 8 HX

Non pumping level 13-4

Manufacturer Peerless

Orifice size 4" meter

Serial No. \_\_\_\_\_

TIME	PIZOMETER READING (IN.)	G. P. M.	AIR GAUGE READING (FEET)	PUMPING LEVEL	DRAWDOWN	DISCH. PRESSURE		TOTAL PUMPING HEAD	TEMP.	REMARKS
						LBS.	FEET			
1:00	0	0		13-4	0		0			START OF TEST
1:05		150		16	2-8					
1:10		150		16-6	3-2					
1:15		150		16-6	3-2					
1:20		150		16-6	3-2					
1:25		150		16-6	3-2					
1:30		150		16-6	3-2					
2:00		150		16-6	3-2					
2:15		150		16-6	3-2					
2:30		150		16-6	3-2					
2:45		150		16-6	3-2					
3:00		150		16-6	3-2					
3:30		150		16-6	3-2					
4:00		150		16-6	3-2					
4:30		150		16-6	3-2					
5:00		150		16-6	3-2					
5:30		150		16-6	3-2					
6:00		150		16-6	3-2					
6:30		150		16-6	3-2					
7:00		150		16-6	3-2					
7:30		150		16-6	3-2					
8:00		150		16-6	3-2					
8:30		150		16-6	3-2					
9:00		150		16-6	3-2					
9:30		150		16-6	3-2					

Continued

# VARNER WELL & PUMP CO.

DUBUQUE, IOWA

## WELL TEST DATA SHEET

Job Oxford Junction

Date tested August 8, 1977

Location City Well #2

Tested by Varner--Paul Gatewood

Dia. of well 8"

Pump used: Driver 471 Detroit

Depth of well 50'

Column and shaft 4" x 1"

Length of air line Electric Probe

Bowls Peerless 8 HX

Non-pumping level 13-4

Manufacturer Peerless

Orifice size 4" meter

Serial No. \_\_\_\_\_

TIME	PISTON METER READING (IN.)	G. P. M.	AIR GAUGE READING (FEET)	PUMPING LEVEL	DRAWDOWN	DISCH. PRESSURE		TOTAL PUMPING HEAD	TEMP.	REMARKS
						LBS.	FEET			
	○	○			○		○			START OF TEST
10:00		150		16-6	3-2					
10:30		150		16-6	3-2					
11:00		150		16-6	3-2					
11:30		150		16-6	3-2					
12:00		150		16-6	3-2					
12:30		150		16-6	3-2					
1:00		150		16-6	3-2					
1:30		150		16-6	3-2					
2:00		150		16-6	3-2					
2:30		150		16-6	3-2					
3:00		150		16-6	3-2					
3:30		150		16-6	3-2					
4:00		150		16-6	3-2					
4:30		150		16-6	3-2					
5:00		150		16-6	3-2					
5:30		150		16-6	3-2					
6:00		150		16-6	3-2					
6:30		150		16-6	3-2					
7:00		150		16-6	3-2					
7:30		150		16-6	3-2					
8:00		150		16-6	3-2					
8:30		150		16-6	3-2					
9:00		150		16-6	3-2					
9:30		150		16-6	3-2					

Continued

# VARNER WELL & PUMP CO.

DUBUQUE, IOWA

## WELL TEST DATA SHEET

Job Oxford Junction, Iowa  
 Location City Well #2  
 Dia. of well 8"  
 Depth of well 50'  
 Length of airline Electric Probe  
 Non-pumping level 13-4  
 Orifice size 4" meter

Date tested August 8, 1977  
 Tested by Varner--Paul Gatewood  
 Pump used: Drive 471 Detroit  
 Column and shaft 4" x 1"  
 Bore Peerless 8 HX  
 Manufacturer Peerless  
 Serial No. \_\_\_\_\_

TIME	PIEZOMETR. READING (IN.)	G. P. M.	AIR GAUGE READING (FEET)	PUMPING LEVEL	DRAWDOWN	DISCH. PRESSURE		TOTAL PUMPING HEAD	TEMP.	REMARKS
						LOG.	FEET			
	○	○			○			○		START OF TEST
10:00		150		16-6	3-2					
10:30		150		16-6	3-2					
11:00		150		16-6	3-2					
11:30		150		16-6	3-2					
12:00		150		16-6	3-2					SHUT DOWN TEST
										WELL RECOVERY
12:01								13'		
12:02								12'11"		
12:03								12'11"		
12:04								12'11"		
12:05								12'11"		
12:06								12'11"		
12:07								12'11"		
12:08								12'11"		
12:09								12'11"		
12:10								12'11"		
12:20								12'11"		
12:30								12'11"		
12:40								12'11"		
12:50								12'11"		
1:00								12'11"		
1:10								12'11"		