

Shawver Well Company, Inc.

2700 Stanley Avenue
Fredericksburg IA 50630

(563) 237-5341
(800) 568-4449

Location of Well				Well Details			
Earlville PWS		County	Delaware	Actual Size	7"	Pump Inst	--
2173 270th Avenue		Township	Oneida	Depth	655'	Liner	-- ft
Earlville, IA 52041		Section	35	SWL	352'	Screen	--
Latitude	42.473964	Quarters	SENESE	RPS	550' @ 15 GPM		
Longitude	-91.271083	T&R		Air Lift	655' @ 20 GPM;	Acidize	-- gal
		Elevation			550' @ 15 GPM	Made Water	63'-65'; 86'-87'; 212'; 520'; 585'
Customer Information				Driller	Dave Halweg Jr		
Dollar General				Driller Cert #	10712		
DuBose, Kyle				State Remarks			
1598 Imperial Ctr, Ste 2001							
West Plains, MO 65775-1855							
Job Information							
Job Use	Business						
PWTS #	PWSID#	Start Date	12/11/2019				
Permit #	2825202	End Date	12/26/2019				
Formation Log				Bore Hole			
From-To	Color	Formation		From-To	Bit Size		
0 - 2	Black	Dirt		0 - 28	12 1/4"		
2 - 4	Brown	Clay		28 - 466	9 7/8"		
4 - 12		Sandy - Clay		466 - 655	6 1/4"		
12 - 16	Blue	Clay					
16 - 17	Tan	Limestone - Soft & Broken					
17 - 21	Tan	Limestone - Soft					
21 - 63	Tan	Limestone					
63 - 65	Tan	Limestone - Soft					
65 - 86	Tan - White	Limestone					
86 - 87	Tan - White	Limestone - Soft					
87 - 140	Tan - White	Limestone					
140 - 262	Tan	Limestone					
262 - 416	Blue	Shale					
416 - 655	Tan - Brown	Limestone					
				Casing or Loops			
From-To		Casing					
+2 - 466		7" OD x .317 Steel					
Screen Details		Liner Details					
Screen Size		Liner Size					
Slot Size		Set From					
Set From		Perforated From					
Riser Pipe							
Tail Pipe							
Grout Consumed							
Amount	Unit	Type					
200	Sk	Neat Cement					