

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

WELL TEST DATA REPORT

Customer City Water Department City Huxley, IA
Location Well Field Well No. 7
Size Casing 16" Total Depth _____ Construction Gravel Pack
Make Pump Grundfos Model No. 625S150 No. of Stages 4
Diameter 8" Total Setting 50' Air Line Length 50'
Meter Used 6" Propeller Static Level 13.5'

DATE	TIME	GPM	P.L.	D.D.	S.C.	PSI	Water Description
09/19/2022	8:00am	820	13.5'				
	8:01	820	19.8'	6.3'	130.15		Clear "0" Sand
	8:02	820	20.1'	6.6'	124.24		
	8:03	820	20.2'	6.7'	122.38	Well #5	Well #6 Off
	8:04	820	20.3'	6.8"	120.58	21' On	17' from top
	8:05	820	20.3'	6.8"	120.58	17' Off	Did not change
	8:06	820	20.4'	6.9"	118.84	Did Not	Throughout test
	8:07	820	20.4'	6.9"	118.84	Change	
	8:08	820	20.4'	6.9"	118.84		
	8:09	820	20.5'	7'	117.14		
	8:10	820	20.5'	7'	117.14		
	8:11	820	20.5'	7'	117.14		
	8:12	820	20.5'	7'	117.14		
	8:13	820	20.5'	7'	117.14		
	8:14	820	20.5'	7'	117.14		
	8:15	820	20.5'	7'	117.14		
	8:18	820	20.5'	7'	117.14		
	8:21	820	20.5'	7'	117.14		
	8:24	820	20.6'	7.1'	115.49		
	8:27	820	20.7'	7.2'	113.88		
	8:30	820	20.8'	7.3'	112.32		
	8:35	820	20.9'	7.4'	110.81		
	8:40	820	20.9'	7.4'	110.81		
	8:45	820	20.9'	7.4'	110.81		
	8:50	820	20.9'	7.4'	110.81		
	8:55	820	20.9'	7.4'	110.81		
	9:00	820	20.9'	7.4'	110.81		
	9:10	820	20.9'	7.4'	110.81		
	9:20	820	21'	7.5'	109.33		

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

WELL TEST DATA REPORT

PAGE -2-

Customer City Water Department
Location Well Field

City Huxley, IA
Well No. 7

DATE	TIME	GPM	P.L.	D.D.	S.C.	P.S.I.	TEMP DISCHARGE DESCRIPTION
09/19/2022	9:30am	820	21'	7.5'	109.33		
	9:40	820	21'	7.5'	109.33		
	9:50	820	21'	7.5'	109.33		
	10:00	820	21'	7.5'	109.33		
	10:10	820	21'	7.5'	109.33		
	10:20	820	21'	7.5'	109.33		
	10:30	820	21'	7.5'	109.33		
	10:40	820	21'	7.5'	109.33		
	10:50	820	20.9'	7.4'	110.81	Well #5	Well #6 17' off
	11:00	820	20.9'	7.4'	110.81	Off 17'	
	12:00	820	20.9'	7.4'	110.81		
	1:00pm	820	20.9'	7.4'	110.81	Well #5	
	2:00	820	20.9'	7.4'	110.81	On 21'	
	3:00	820	20.9'	7.4'	110.81		
	4:00	820	20.9'	7.4'	110.81		
	5:00	820	20.9'	7.4'	110.81		
	6:00	820	20.9'	7.4'	110.81		
	7:00	820	20.9'	7.4'	110.81		
	8:00	820	20.9'	7.4'	110.81		
	9:00	820	20.9'	7.4'	110.81		
	10:00	820	20.9'	7.4'	110.81		
	11:00	820	20.9'	7.4'	110.81		
09/20/2022	12:00	820	20.9'	7.4'	110.81		
	1:00	820	20.9'	7.4'	110.81		
	2:00	820	20.9'	7.4'	110.81		
	3:00	820	20.9'	7.4'	110.81		
	4:00	820	21'	7.5'	109.33		
	5:00	820	21'	7.5'	109.33		
	6:00	820	21'	7.5'	109.33		
	7:00	820	21'	7.5'	109.33		

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

PAGE -3-

City Huxley, IA
Well No. 7

[illegible]